

ADDENDUM No. 1

To

Auburn Water District Invitation for Quotes for Office Emergency Generator Replacement January 13, 2025

This Addendum No. 1 forms part of the Invitation for Quote package and modifies text in Section 1 and Section 2 to reflect that the proposal is for a single-phase generator and *not* a three-phase generator. Below are the updated portions of the document to reflect the changes.

No changes were required to be made to Appendix A or Appendix B.

1. General Information and Quote Submission Requirements

The Auburn Water District (District) seeks quotes under M.G.L. Ch. 30 Sec. 39M for a contract to replace a 30kw **single-phase**, natural gas generator and automatic transfer switch, and if required, any associated gas and/or electrical piping.

2. Scope of Services

- Supply and install a new 30KW 120/240V, **Single** Phase Generator Natural Gas Generator (see attached Section 16232 – Packaged Engine Generator Systems (Natural Gas)).